

Message Text

CONFIDENTIAL

PAGE 01 STATE 099582
ORIGIN SY-05

INFO OCT-01 AF-10 EUR-12 ISO-00 FBO-02 /030 R

DRAFTED BY A/SY/OPS/T: L A JACKSON:TEA
APPROVED BY A/SY/OPS/T: D G FISCHER, CHIEF
A/SY/OPS/T: W GILLIAM
DESIRED DISTRIBUTION
SY/FO/AF

-----031432Z 109880 /43

R 031404Z MAY 77
FM SECSTATE WASHDC
TO AMEMBASSY ABIDJAN
AMEMBASSY DAKAR
AMCONSUL FRANKFURT

C O N F I D E N T I A L STATE 099582

ABIDJAN FOR TSO; RSO; DAKAR FOR PSO; FRANKFURT FOR OIC/RTC

E.O. 11652: GDS

TAGS: ASEC

SUBJECT: ACR INSTALLATION - DAKAR

REF: STATE

1. PROPOSED ACR INSTALLATION SURVEY NOB DAKAR RECEIVED AT
SY/OPS/T. SY/OPS/T CONCURS WITH PROPOSED INSTALLATION. THE
FOLLOWING ARE COMMENTS AND SUGGESTIONS REGARDING PROPOSED
INSTALLATION.

A. SURVEY DRAWING INDICATES TWO EACH INLETS AND EX-
HAUSTS AT THE ACR. ACTUAL INSTALLATION WILL HAVE ONE EACH
INLET AND EXHAUST INSTALLED ON THE SAME OR OPPOSITE SIDES
OF THE SIDE WALLS.

CONFIDENTIAL

CONFIDENTIAL

PAGE 02 STATE 099582

B. ITEM 28 TRANSITION IS NOT REQUIRED. THE PROPER
TRANSITION IS SUPPLIED WITH THE SHELDAHL ACR.

C. SUGGEST CONSULTATION WITH FBO PROJECT SUPERVISOR
REGARDING CFM OF FAN COIL UNIT. 750 CFM FAN COIL UNITS NOR-
MALLY INSTALLED WHICH ARE CAPABLE OF PROVIDING PROPER AIR

EXCHANGE FOR ACR, THUS ELIMINATING NEED FOR THE INLINE BOOSTER FAN, ITEM 27.

D. SUGGEST INSTALLATION OF REMOVABLE PLYWOOD PANELS

OVER PARENT ROOM WINDOWS. PANELS WOULD BE INSTALLED FLUSH WITH PARENT ROOM WALL. DRAPES COULD BE LEFT AT WINDOWS TO GIVE A NORMAL APPEARANCE. THIS KIND OF INSTALLATION WOULD ELIMINATE THE NEED FOR ITEM 13 (WALL) AND ADD APPROXIMATELY 18 INCHES TO THE PARENT ROOM.

2. ACR CHAIRS ARE ON ORDER BUT NOT YET RECEIVED. REQUESTED QUANTITY OF CHAIRS CAN BE SHIPPED AS SOON AS RECEIVED FROM THE MANUFACTURER.

3. A 12 FOOT BY 18 FOOT ACR IS PRESENTLY IN STORAGE AT THE MILITARY OCEAN TERMINAL (MOT), BAYONNE, N.J. ARRANGEMENTS WILL BE MADE TO SHIP THE ACR TO DAKAR.

4. FOR DAKAR: HOW MANY CHAIRS ARE IN THE PRESENT 9' X 12' ACR? WHAT IS THE CONFERENCE TABLE SIZE?

5. PLEASE ADVISE ANY SPECIAL SHIPPING INSTRUCTIONS. SHIPMENT WILL BE MANIFESTED AS OFFICE FURNITURE.

6. PRESENT 9' X 12' ACR SHOULD BE DISASSEMBLED, CLEANED, PACKED FOR SHIPMENT, AND STORED IN SECURE AREA. EXACT DISPOSITION OF ACR UNKNOWN AT THIS TIME.

CONFIDENTIAL

CONFIDENTIAL

PAGE 03 STATE 099582

7. SHIPMENT OF ILG NOISE GENERATORS PRESENTLY IN ROUTE TO RTC FRANKFURT. OIC/RTC FRANKFURT IS HEREBY REQUESTED TO SHIP TWO EACH ILG NOISE GENERATORS TO AMEMBASSY, DAKAR, ATTENTION PSO. PSO DAKAR TO HOLD FOR TSO ABIDJAN.

8. FLEXIBLE DUCTING WILL BE FORWARDED FROM SY/OPS/T.

9. YOU WILL BE ADVISED ETA ALL ITEMS WHEN DETERMINED.
VANCE

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01-Jan-1994 12:00:00 am
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Sent Date: 03-May-1977 12:00:00 am
Decaption Date: 01-Jan-1960 12:00:00 am
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 22 May 2009
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1977STATE099582
Document Source: CORE
Document Unique ID: 00
Drafter: L A JACKSON:TEA
Enclosure: n/a
Executive Order: GS
Errors: N/A
Expiration:
Film Number: D770154-1057
Format: TEL
From: STATE
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1977/newtext/t19770599/aaaadhoi.tel
Line Count: 106
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: dbcd309b-c288-dd11-92da-001cc4696bcc
Office: ORIGIN SY
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: 77 STATE 76
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 03-Feb-2005 12:00:00 am
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 2653807
Secure: OPEN
Status: NATIVE
Subject: ACR INSTALLATION - DAKAR
TAGS: ASEC
To: ABIDJAN DAKAR MULTIPLE
Type: TE
vdkgvwkey: odbc://SAS/SAS.dbo.SAS_Docs/dbcd309b-c288-dd11-92da-001cc4696bcc
Review Markings:
Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
22 May 2009
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009